



POTVRDA O TIPNOM ODOBRENJU
TYPE APPROVAL CERTIFICATE

Br /No 01-009782/016722

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju brodova, Dio 1. - Opci propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:

TYPE AND DESCRIPTION OF PRODUCT:

SUSTAV STROPNIH PANELA SSP-2, KLASSE "B-0"

CEILING PANEL SYSTEM SSP-2, "B-0" CLASS

PROIZVOĐAC:

MANUFACTURER:



PROIZVOD UDOVOLJAVA SLIJEDECIM PRAVILIMA/PROPISIMA:

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za klasifikaciju pomorskih brodova, Dio 17. – Protupožarna zaštita; Medunarodna Konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama; IMO FTP Kodeks; IMO Rezolucija A.754(18).

Rules for the Classification of Sea-Going Ships, Part 17 – Fire protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended; IMO FTP Code; IMO Resolution A.754(18).

DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEĐINI.

FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRIJEDI DO: 2017-03-21
APPROVAL IS VALID UNTIL:

Mjesto i datum: Split, 2013-03-27
Place and date:

M.P.
(Seal)

Goran Begovic, dipl.ing.

NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

PODROBNJI OPIS PROIZVODA:
DETAILED PRODUCT DESCRIPTION:

Jedinicni element sustava stropnih panela je panel od celicnog pocincanog lima debljine 0,6 mm iznutra izoliran s mineralnom vunom "TERVOL DP-3", debljine 25 mm, gustoce $30 \pm 10\%$ kg/m³.

Basic element of ceiling panel system is 0,6 mm thick galvanised steel panel insulated inside with 25 mm thick "TERVOL DP-3" mineral wool board, density $30 \pm 10\%$ kg/m³.

PODRUCJE PRIMJENE / POSEBNI GRANICNI UVJETI:
APPLICATION / LIMITATIONS:

Protupožarna zaštita klase "B-0" na brodovima.

"B-0" class fire protection on ships.

DOKUMENTACIJA ZA TIPNO ODOBRENJE:
TYPE APPROVAL DOCUMENTATION:

Sustav stropnih panela SSP-2, klase "B-0" konstruiran je prema nacrtima br. 12-678 i 12-678-935.

Ispitivanje u skladu s IMO Rezolucijom A.754(18) izvršeno je u ZAVOD ZA GRADBENIŠTVO, Ljubljana, POŽARNI LABORATORIJ, Ljubljana. Rezultati ispitivanja navedeni su u izvješću o ispitivanju br. P-133/00-530-1, od 21. veljace 2000.

Ceiling panel system SSP-2, "B-0" class is constructed in accordance with the drawings No.12-678 and 12-678-935. The testing in accordance with IMO Resolution A.754(18) have been carried out in ZAVOD ZA GRADBENIŠTVO, Ljubljana, POŽARNI LABORATORIJ, Ljubljana. The testing results have been stated in the Test Report No. P-133/00-530-1, dated February 21 2000.

OZNACAVANJE PROIZVODA:
MARKING OF PRODUCT:

Proizvod ili pakiranje mora se oznaciti imenom proizvođača, oznakom proizvoda i protupožarnom klasom te žigom HRB.

The product or packing is to be marked with name of manufacturer, type designation, fire-technical rating and CRS stamp.

UVJETI ZA CERTIFIKACIJU:
CONDITIONS FOR CERTIFICATION:

Hrvatski registar brodova izdaje posebnu potvrdu o nadzoru za svaku pojediniu proizvedenu količinu (HRB obrazac QF-PB-09).

Croatian Register of Shipping shall issue particular certificate on supervision for each manufactured quantity (CRS form QF-PB-09).

Račlana

17.02.02.00

Zamjenjuje potvrdu

01-007885