CROATIAN REGISTER OF SHIPPING



Certificate No.

01-013241/019795

TYPE APPROVAL CERTIFICATE

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TYPE AND DESCRIPTION OF PRODUCT:

MOBILE (WHEELED) POWDER FIRE EXTINGUISHER, Capacity 25 kg Type 14134_10

MANUFACTURER:

A.B.S. s.r.l.

Viale Lombardia, 310 20861 Brugherio (MB) ITALY

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Rules for the classification of ships, Part 17-Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.

FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

APPROVAL IS VALID UNTIL: 2023-03-14

Place and date: Split, 2019-03-14 Seal

Marinko Popović, dipl.ing.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

QF-PTO-01 1/2 2019-03



Certificate No.

01-013241/019795

DETAILED PRODUCT DESCRIPTION:

Mobile (wheeled) powder fire extinguisher, Type 14134_10

Cylinder material: steel AISI 304, DD12 EN 10111

Cylinder dimensions (external diameter/height): 245/795 mm

Valve body material: brass Cylinder capacity: 33 l

Extinguishing agent type and quantity: Powder "Furex ABC 30", 25 kg

Operating temperature range: -30° C to $+60^{\circ}$ C Fire rating according to EN 1866-1: A – IVB - C

Operation: External propellant gas cartridge (2l Nitrogen-N₂, 140 bar/20°C)

APPLICATION / LIMITATIONS:

Extinguishing of class A, B and C fires on ships.

TYPE APPROVAL DOCUMENTATION:

Test report No. 1427-2009 dated 17.07.2009. issued by Istituto Masini S.r.l.

Drawings attached to the Test report:

No. 18131_10 dated 20.04.2009., no. 21818 dated 21.04.2009., no. 27704 dated 20.04.2009., no.21034, and no.21042 dated 20.04.2009., no.20519 dated 21.04.2009., no. 20088 dated 20.04.2009., no. 20640 dated 20.04.2009., no. 21035 dated 20.04.2009., no.21931 dated 13.11.2000. and no. 21090 dated 20.04.2009.

MARKING OF PRODUCT:

Each mobile fire extinguisher shall be marked with: manufacturer's name, type of product and date of manufacture (month and year).

CONDITIONS FOR CERTIFICATION: