



Potvrda br.  
Certificate No.

01-013821/0110297

## POTVRDA O TIPNOM ODOBRENJU TYPE APPROVAL CERTIFICATE

Potvrđuje se da ovaj proizvod udovoljava Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda.  
This is to certify that this product complies with the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TIP I OPIS PROIZVODA:  
TYPE AND DESCRIPTION OF PRODUCT:

**PROTUPOŽARNI RAVNI VENTIL DN 40, 50, 65 - PN 16**  
FIRE FLAT VALVE DN 40, 50, 65 – PN 16

**PROTUPOŽARNI KUTNI VENTIL DN 40, 50, 65 - PN 16**  
FIRE ANGULAR VALVE DN 40, 50, 65 – PN 16

PROIZVOĐAČ:  
MANUFACTURER:



**KOMPAS NOVA d.o.o.**  
Milutina Barača 58, 51000 RIJEKA  
HRVATSKA • CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:  
THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

**Pravila za klasifikaciju brodova, Dio 17. - Protupožarna zaštita; Međunarodna konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama.**  
Rules for the classification of ships, Part 17- Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.

DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEĐINI.  
FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRIJEDI DO: **2023-02-22**  
APPROVAL IS VALID UNTIL:

Mjesto i datum: Split, 2019-11-27  
Place and date:

M.P.  
(Seal)

Marinko Popović, dipl.ing.

**NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.**  
NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

**PODROBNJI OPIS PROIZVODA:**  
*DETAILED PRODUCT DESCRIPTION:*

**Ručno upravljani protupožarni ventili (ravni ili kutni) s prirubničkim spojem.**

**Nazivna veličina: DN 40, 50 i 65**

**Nazivni pritisak: 16 bara**

*Manually operated fire valves (flat or angular) with flanged inlet.*

*Nominal size: DN 40, 50 and 65*

*Nominal pressure: 16 bar*

**PODRUČJE PRIMJENE / POSEBNI GRANIČNI UVJETI:**  
*APPLICATION / LIMITATIONS:*

**Protupožarna oprema na brodovima.**

*Fire fighting equipment on ships.*

**DOKUMENTACIJA ZA TIPNO ODOBRENJE:**  
*TYPE APPROVAL DOCUMENTATION:*

**Nacrti br. K-051(16 listova), K-052(3 lista), K-071(13 listova), K-072(2 lista), K-090(2 lista), K-091, K-092 i K-093.**

**Rezultati ispitivanja navedeni su u izvješćima o ispitivanju od 1998-04-03 i 2007-09-06.**

*Drawings No. K-051(16 pages), K-052(3 pages), K-071(13 pages), K-072(2 pages), K-090(2 pages), K-091, K-092 and K-093.*

*The testing results have been stated in the Test Reports dated 1998-04-03 and 2007-09-06.*

**OZNAČAVANJE PROIZVODA:**  
*MARKING OF PRODUCT:*

**Svaki pojedini ventil mora imati slijedeće oznake: ime proizvođača, oznaka proizvoda i broj šarže.**

*Each valve shall be marked with: name of manufacturer, type of product and heat number.*

**UVJETI ZA CERTIFIKACIJU:**  
*CONDITIONS FOR CERTIFICATION:*

-