



Potvrda br.
Certificate No.

01-015092/0111503

POTVRDA O TIPNOM ODOBRENJU TYPE APPROVAL CERTIFICATE

Potvrđuje se da ovaj proizvod udovoljava Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda.
This is to certify that this product complies with the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TIP I OPIS PROIZVODA:
TYPE AND DESCRIPTION OF PRODUCT:

PRENOSIVI SLOG ZA PJENU TIP 400

PORTABLE FOAM APPLICATOR UNIT TYPE 400

PROIZVOĐAČ:
MANUFACTURER:



KOMPAS NOVA d.o.o.
Milutina Barača 58, 51000 RIJEKA
HRVATSKA • CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:
THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za klasifikaciju brodova, Dio 17. - Protupožarna zaštita; Međunarodna konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama.

Rules for the classification of ships, Part 17- Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.

DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEĐINI.
FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRIJEDI DO: 2025-12-31
APPROVAL IS VALID UNTIL:

Mjesto i datum: Split, 2021-12-23
Place and date:

M.P. _____
(Seal)

Marinko Popović, dipl.ing.

NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

PODROBNJI OPIS PROIZVODA:
DETAILED PRODUCT DESCRIPTION:

Prenosivi slog za pjenu, za priključenje na glavni sustav gašenja požara, sastoji se od:

- ručne mlaznice pjene tip "MTP-400";
- mješača pjene tip "PMP 400";
- dvije posude koncentrata odobrene pjene zapremine 20 l;
- dvije protupožarne cijevi duljine 15 m s fiksnim spojnica ND 52 na obje strane;
- gumene cijevi za priključenje posude na mješač.

Portable foam applicator unit, for connection to the fire main, consisting of:

- air-foam nozzle type "MTP-400";
- in-line inductor type "PMP 400";
- two portable tanks each containing 20 litres approved foam concentrate;
- two fire hoses 15 m length with fixed couplings ND 52 on each end;
- pick-up tube for connection of the in-line inductor to the portable tank.

PODRUČJE PRIMJENE / POSEBNI GRANIČNI UVJETI:
APPLICATION / LIMITATIONS:

Protupožarna oprema za gašenje požara na brodovima.

Tlak na ulazu mora biti najmanje 0,1 MPa.

Koncentrat pjene niskog stupnja ekspanzije mora biti ispitano i odobreno u skladu s IMO MSC.1/Circ.1312, uključivo i MSC.1/Circ.1312/Corr.1.

Fire extinguishing equipment on ships.

Inlet pressure at least 0.1 MPa.

The foam concentrate shall be tested and approved acc. to MSC.1/Circ.1312 including MSC.1/Circ.1312/Corr.1.

DOKUMENTACIJA ZA TIPNO ODOBRENJE:
TYPE APPROVAL DOCUMENTATION:

Mlaznica za tešku pjenu tip "MTP-400", br. nacrti K-120 (6 listova).

Prenosivi mješač pjene tip "PMP 400", br. nacrti K-210 (28 listova).

Izveštaj o tipnom ispitivanju od 06. rujna 2007.

Air-foam nozzle type "MTP-400", drawing No. K-120 (6 sheets).

In-line inductor type "PMP 400", drawing No. K-210 (28 sheets).

Testing report dated 06th September 2007

OZNAČAVANJE PROIZVODA:
MARKING OF PRODUCT:

Proizvod se mora označiti imenom proizvođača, oznakom proizvoda i žigom HRB.

The product shall be marked with name of manufacturer, type designation and CRS stamp.

UVJETI ZA CERTIFIKACIJU:
CONDITIONS FOR CERTIFICATION:

-